

# 2021 Water Quality Report for the Village of Edwardsburg

This report covers the drinking water quality for The Village of Edwardsburg water system for the 2021 calendar year. This information is a snapshot of the quality of the water that we provided to you in 2021. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards.


Your water comes from two groundwater wells, each over 150 feet deep. The State performed an assessment of our source water to determine the susceptibility or the relative potential of contamination. The susceptibility rating is on a seven-tiered scale from "very-low" to "very-high" based on geologic sensitivity, well construction, and water chemistry and contamination sources. The susceptibility of our source is moderately low for each of our wells.

There are no significant sources of contamination in our water supply. We are making efforts to protect our sources by enacting a wellhead protection program in 2014; perhaps you have seen our "Drinking Water Protection" signs along the roadway. If you would like to know more about the report, please contact Rich Low Water Superintendent at the village hall 269-663-8484 or by e-mail at [voe\\_water@comcast.net](mailto:voe_water@comcast.net).

- **Contaminants and their presence in water:** Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **EPA's Safe Drinking Water Hotline (800-426-4791)**.

- **Vulnerability of sub-populations:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

- **Sources of drinking water:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.
- Contaminants that may be present in source water include:
  - **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
  - **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
  - **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.
  - **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.
  - **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also, come from



gas stations, urban stormwater runoff, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.

## Water Quality Data

The table below lists all the drinking water contaminants that we detected during the 2021 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 – December 31, 2021. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All of the data is representative of the water quality, but some are more than one year old.

### Terms and abbreviations used below:

- **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Residual Disinfectant Level Goal (MRDLG):** means the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **N/A:** Not applicable **ND:** not detectable at testing limit **ppb:** parts per billion or micrograms per liter **ppm:** parts per million or milligrams per liter **pCi/l:** picocuries per liter (a measure of radioactivity).
- **Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
- **Level 1 Assessment:** A study of the water supply to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
- **Level 2 Assessment:** A very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

| Regulated Contaminant                              | MCL          | MCLG  | Level Detected              | Range     | Year Sampled | Violation Yes / No                            | Typical Source of Contaminant  |
|--|--------------|-------|-----------------------------|-----------|--------------|---|--|
| Nitrate (ppm)                                      | 10           | 10    | ND                          | n/a       | 2021         | no  | Septic tanks, application of nitrogen rich fertilizers, and agricultural processes.                              |
| Arsenic  | 0.010        | 0     | ND                          | n/a       | 2020         | no  | Natural deposits or industrial and agricultural pollution  |
| Barium (ppm)                                       | 2            | 2     | 0.08                        | n/a       | 2013         | no  | Discharge of drilling wastes; Discharge of metal refineries; Erosion of natural deposits                         |
| TTHM - Total Trihalomethanes (ppb)                 | 80           | N/A   | 0.0030                      | n/a       | 2021         | no  | Byproduct of drinking water disinfection   |
| HAA5 Haloacetic Acids (ppb)                        | 60           | N/A   | ND                          | n/a       | 2021         | no  | Byproduct of drinking water disinfection   |
| Chlorine* (ppm)                                    | MRDL         | MRDLG | 0.60                        | 0.56-0.63 | 2021         | no  | Water additive used to control microbes  |
|  | 4            | 4     |                             |           |              |   |  |
| Contaminant Subject to AL                          | Action Level | MCLG  | 90% of Samples ≤ This Level |           | Year Sampled | Number of Samples Above AL                    | Typical Source of Contaminant  |
| Lead (ppb) **                                      | 15           | 0     | 3                           |           | 2021         | 0   | Lead service lines, corrosion of household plumbing including fittings and fixtures; Erosion of natural deposits |
| Copper (ppm)                                       | 1.3          | 1.3   | 0.1                         |           | 2021         | 0   | Corrosion of household plumbing systems; Erosion of natural deposits   |
| Special Monitoring and Unregulated Contaminant *** |              |       | Level Detected              |           | Year Sampled | Comments                                      |  |
| Sodium (ppm)                                       |              |       | 11ppm                       |           | 2021         | Typical source is erosion of natural deposits |  |

|          |         |      |   |
|----------|---------|------|---|
| Hardness | 337ppm  | 2021 | Results of monitoring are available upon request. |
| Chloride | 26ppm   | 2021 | Results of monitoring are available upon request  |
| Iron     | 1.3 ppm | 2021 | Results of monitoring are available upon request  |
| Sulfate  | 45 ppm  | 2021 | Results of monitoring are available upon request  |

\* Chlorine was calculated using the running annual average.

\*\* 90 percent of the samples collected were at or below the level reported for our water.

\*\*\* Unregulated contaminants are those for which EPA has not established drinking water standards. Monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants.

| Date collected | Sampling location | PFOS+PFOA (ppt) | LHA (ppt)<br>PFOS+PFOA | Total tested<br>PFAS (ppt) |
|----------------|-------------------|-----------------|------------------------|----------------------------|
| 9/22/21        | TO012             | ND              | 70                     | ND                         |
|                |                   |                 |                        |                            |

**Information about lead:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Edwardsburg Water Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

*Infants and children who drink water containing lead could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.*

Monitoring and Reporting to the DEQ Requirements: The State and EPA require us to test our water on a regular basis to ensure its safety. The Village met all monitoring requirements but received 2 reporting violations for 2021 by not meeting the required deadline for submitting.

We will update this report annually and will keep you informed of any problems that may occur throughout the year, as they happen. Copies are available at the village hall.

A full system flush is being done twice a year to improve the water clarity of our system. A complete tower cleaning every is scheduled every 18 months, The Village is currently in the process finalizing plans for an Iron removal plant to further improve the water quality. These tasks are in place to assure water quality and to protect the life of our water system.

We invite public participation in decisions that affect drinking water quality. The village council meets the third Monday of the month at the village hall. For more information about your water, or the contents of this report, contact Rich Low Water Superintendent either by phone 269-663-8484 or e-mail at [voe\\_water@comcast.net](mailto:voe_water@comcast.net) . For more information about safe drinking water, visit the U.S. Environmental Protection Agency at [www.epa.gov/safewater/](http://www.epa.gov/safewater/).

Thank You

Rich Low  
Water Superintendent

